



TEST METHOD FOR
MEASUREMENT OF HOT CREEP
OF POLYMERIC INSULATIONS

Approved by
AMERICAN NATIONAL STANDARDS INSTITUTE

May 10, 2004

Publication # ANSI/ICEA T-28-562-2003

Reaffirmed September 12, 2014

©2003

by

INSULATED CABLE ENGINEERS ASSOCIATION, Inc.



Approved as an American National Standard
ANSI Approval Date: May 10, 2004

Insulated Cable Engineers Assoc., Publication No. T-28-562-Revised 2003 (R2014)

Test Method For Measurement Of Hot Creep Of Polymeric Insulations

Published by

Insulated Cable Engineers Association

P.O. Box 2694

Alpharetta, Georgia 30023

www.icea.net

© Copyright 2003 by the Insulated Cable Engineers Association. All rights including translation into other languages, reserved under the Universal Copyright Convention, the Berne Convention for the Protection of Literary and Artistic Works, and the International and Pan American Copyright Conventions.

NOTICE AND DISCLAIMER

The information in this publication was considered technically sound by the consensus of persons engaged in the development and approval of the document at the time it was developed. Consensus does not necessarily mean that there is unanimous agreement among every person participating in the development of this document.

The Insulated Cable Engineers Association, Inc. (ICEA) standards and guideline publications, of which the document contained herein is one, are developed through a voluntary consensus standards development process. This process brings together persons who have an interest in the topic covered by this publication. While ICEA administers the process and establishes rules to promote fairness in the development of consensus, it does not independently test, evaluate, or verify the accuracy or completeness of any information or the soundness of any judgements contained in its standards and guideline publications.

ICEA disclaims liability for personal injury, property, or other damages of any nature whatsoever, whether special, indirect, consequential, or compensatory, directly or indirectly resulting from the publication, use of, application, or reliance on this document. ICEA disclaims and makes no guaranty or warranty, expressed or implied, as to the accuracy or completeness of any information published herein, and disclaims and makes no warranty that the information in this document will fulfill any of your particular purposes or needs. ICEA does not undertake to guarantee the performance of any individual manufacturer or seller's products or services by virtue of this standard or guide.

In publishing and making this document available, ICEA is not undertaking to render professional or other services for or on behalf of any person or entity, nor is ICEA undertaking to perform any duty owed by any person or entity to someone else. Anyone using this document should rely on his or her own independent judgement or, as appropriate, seek the advice of a competent professional in determining the exercise of reasonable care in any given circumstances. Information and other standards on the topic covered by this publication may be available from other sources, which the user may wish to consult for additional views or information not covered by this publication.

ICEA has no power, nor does it undertake to police or enforce compliance with the contents of this document. ICEA does not certify, test, or inspect products, designs, or installations for safety or health purposes. Any certification or other statement of compliance with any health or safety-related information in this document shall not be attributable to ICEA and is solely the responsibility of the certifier or maker of the statement.

CONTENTS

	Page
Foreword.....	ii
Scope.....	iii
Section 1 Apparatus.....	Error! Bookmark not defined.
1.1 Air Oven	Error! Bookmark not defined.
1.2 Specimen Support.....	Error! Bookmark not defined.
Section 2 Specimen	Error! Bookmark not defined.
2.1 Wire Sizes smaller than 6 AWG	Error! Bookmark not defined.
2.2 Wire Sizes 6 AWG and Larger	Error! Bookmark not defined.
Section 3 Procedure.....	Error! Bookmark not defined.
3.1 Elongation Test	Error! Bookmark not defined.
3.2 Set Test.....	Error! Bookmark not defined.
Section 4 Report	Error! Bookmark not defined.

Foreword

ICEA publications are adopted in the public interest and are designed to eliminate misunderstanding between the manufacturer and user and to assist the user in selecting and obtaining proper products for his particular need. Existence of an ICEA publication does not in any respect preclude the manufacture or use of products not conforming to the publication. The user of this publication is cautioned to observe any health or safety regulations and rules relative to the manufacture and use of cable covered by this document. T-28-562 was reaffirmed and approved by ICEA in April 2003.

Suggestions for improvements in this publication are welcome, and should be sent to ICEA at the address below.

Insulated Cable Engineers Association, Inc.
P.O. Box 2694
Alpharetta, GA 30023

Scope

This test method provides a procedure, which is suited for determining the relative degree of crosslinking of polymeric, electric cable insulations.

Summary of Method:

Elongation Test: A specimen is subjected to a constant load stress while suspended in an air oven at a specified elevated temperature for a specified time period. At the end of the time period the increase in elongation of the specimen is determined.

Set Test: Immediately after the elongation test has been completed on a specimen, the same specimen with the load stress removed, will be subjected to an additional time period in the oven at the same elevated temperature. The specimen is then removed and allowed to cool. The set of the specimen, based on original length, is then determined.

Significance:

The test method has a consistent reproducibility, which makes it particularly suitable as a quality control test for determining relative degree of crosslinking. This method has been found more reproducible than the other methods in current use such as heat deformation. Also, it corresponds more closely to service conditions than a solvent-extraction procedure.